

Question 26 (translated from French):

Could Hydro-Québec TransÉnergie's exploratory study report provide us with details on the level of receptivity of the connecting zone?

For instance, could we be informed on the total integration capacity (in MW) available for the line indicated by Hydro-Québec TransÉnergie and/or for all the lines of the system for that zone?

Answer 26 :

The exploratory study request form must indicate to Hydro-Québec TransÉnergie the generating capacity to be integrated to the system, that is to say a capacity of no more than 25 MW per project. The exploratory study report provides information on the integration solution foreseen by Hydro-Québec TransÉnergie, without giving details on the level of receptivity of the connection zone.

Although the exploratory study report does not indicate the level of receptivity of Hydro-Québec TransÉnergie's installations, he can recommend a reduction of the generating capacity if this entails a significant reduction of the connecting costs in \$ / MW.