

Projet QC-2014-02
Questions and answers – Information session

Information session on January 15, 2015 at 3:30

Reliability Coordinator personnel

Presenters : Martin Boisvert, Mathieu Péroquin, Émile Khan

Presents : Caroline Dupuis, Si Truc Phan, Santiago Pineiro, Alain Côté, Chantal Mazza

Entites et organisations presents

TransAlta Corporation (TransAlta), Rio Tinto Alcan (RTA), Hydro-Québec Production (HQP), Hydro-Québec TransÉnergie (HQT), Énergie Brookfield Marketing s.e.c.

This document is a summary of questions asked by the entities and answers given by the reliability coordinator during the information session of January 15, 2015 related to the project QC-2014-02.

1 RTA

Q: What is the deadline for completing the evaluations?

A : The consultation period ends February 2, 2015.

2 RTA

Q: How will the RC, the PC or the TP advise the entity that an asset is designated and identified as being essential in the calculation of the IROLs (as part of the implementation of CIP-002-5.1 – Annexe 1)? Without this information, we are not able to evaluate the impact as requested by the Coordinator

A: When the standard becomes effective, the RC or the PC will notify the affected entities. There is an additional time allowed for assets that are identified as such, following the entry into force. Regarding your impact assessment, none of your facilities meet this criterion.

So far we have no indication to the effect that the PC will identify generation facilities that would be subject to the CIP-002-5 standard beyond 1,500 MW of the first criterion that was presented. Until now, only HQT transmission facilities and HQP generation facilities used for derivation of IROLs are included in this calculation. This new version of the standard does not extend the scope to additional facilities.

3 RTA

Q: Is it possible to extend the comment period?

A: You can make a written request by sending an email to the address fiabilite@hydro.qc.ca.