

**Appendix PRC-030-1-QC-1**  
**Specific provisions applicable in Québec for standard**  
**PRC-030-1 – Unexpected Inverter-Based Resource Event Mitigation**

---

This appendix establishes specific provisions for the application of the standard in Québec. Provisions of the standard and of this appendix must be read jointly for comprehension and interpretation purposes. Where the standard and appendix differ, the appendix shall prevail.

**A. Introduction**

- 1. Title:** No specific provisions.
- 2. Number:** No specific provisions.
- 3. Purpose:** No specific provisions.
- 4. Applicability:** In the application of this standard, all reference to the term “Bulk Electric System” or “BES” shall be replaced by the terms “Main Transmission System” or “RTP” respectively.

The Facilities subject to this standard are the Facilities of the Main Transmission System (RTP).

**4.1. Functional Entities:**

No specific provisions.

**4.2. Facilities:**

**4.2.1** No specific provisions.

**4.2.2** Non-RTP Inverter-Based Resources that either have or contribute to an aggregate nameplate capacity of greater than or equal to 50 MVA, connected through a system designed primarily for delivering such capacity to a common point of connection at a voltage greater than or equal to 44 kV.

**5. Effective Date:**

- |             |  |            |
|-------------|--|------------|
| <b>5.1.</b> | Adoption of the standard by the Régie de l'énergie:        | MM DD YYYY |
| <b>5.2.</b> | Adoption of the appendix by the Régie de l'énergie:        | MM DD YYYY |
| <b>5.3.</b> | Effective date of the standard and its appendix in Québec: | MM DD YYYY |

**Appendix PRC-030-1-QC-1**  
**Specific provisions applicable in Québec for standard**  
**PRC-030-1 – Unexpected Inverter-Based Resource Event Mitigation**

---

Requirements	Applicability	Date of implementation in Québec
R1 to R4	For RTP Inverter-Based Resources	No later than the effective date of PRC-030-1
R1 to R4	For Non-RTP Inverter-Based Resources	At the latest of the following dates:  The effective date of PRC-029-1  OR  Within two (2) calendar years of the effective date of PRC-030-1

**B. Requirements and Measures**

No specific provisions.

**C. Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Enforcement Authority**

In Québec, “Compliance Enforcement Authority” means the Régie de l’énergie in its roles of monitoring and enforcing compliance with respect to the Reliability Standard and to this appendix.

**1.2. Evidence Retention**

No specific provisions.

**1.3. Compliance Monitoring and Enforcement Program:**

No specific provisions.

**Violation Severity Levels**

No specific provisions.

**D. Regional Variances**

No specific provisions.

**E. Associated Documents**

No specific provisions.

**Version History**

Version	Date	Action	Change Tracking
1	MM DD YYYY	New Appendix as per decision D-2xxx-xxx.	New