

Power plants with minimum outflow to be maintained

Beauharnois et Gatineau					
Cabonga					
			4,2	total flow (m ³ /s)	Minimum
Rapides-Farmers					
	april 1st to july 31		110	total flow (m ³ /s)	Minimum
	august 1st to march 31		100	total flow (m ³ /s)	Minimum
Des Cascades					
Chute-Allard					
			1	spill (m ³ /s)	Minimum
Chute-Hemmings					
			7	total flow (m ³ /s)	Minimum
Rapides-des-Coeurs					
			1	spill (m ³ /s)	Minimum
Sept-Chutes					
	january 1st to april 30		1	spill (m ³ /s)	Minimum
	november 1st to december 31		1,5	spill (m ³ /s)	Minimum
	may 1st to october 31		3	spill (m ³ /s)	Minimum
La Grande Rivière					
Eastmain					
			140	total flow (m ³ /s)	Minimum
La Grande-1					
			850	total flow (m ³ /s)	Minimum
Rapides-des-Quinze					
			1	spill (m ³ /s)	Minimum
Manicouagan					
Bersimis-2					
	july 1st to november 14		93	water discharged (m ³ /s)	Minimum
	november 15 to june 30		186	water discharged (m ³ /s)	Minimum
Hart-Jaune					
	april 1st to november 14		11	total flow (m ³ /s)	Minimum
	november 15 to march 31		16	total flow (m ³ /s)	Minimum
Romaine-2					
			2,7	spill (m ³ /s)	Minimum
Sainte-Marguerite-3					
			33	total flow (m ³ /s)	daily minimum
			44	flow (m ³ /s)	monthly summer minimum
			55	flow (m ³ /s)	average summer minimum

Touloustouc					
	may 15 to may 31		6	spill (m ³ /s)	Minimum
	june 1st to june 30		9	spill (m ³ /s)	Minimum
	july 1st to september 15		10	spill (m ³ /s)	Minimum
	september 16 to mai 14		3	spill (m ³ /s)	Minimum

