

A. Introduction

1. **Title:** Generator Frequency and Voltage Protective Relay Settings
2. **Number:** PRC-024-2
3. **Purpose:** Ensure Generator Owners set their generator protective relays such that generating units remain connected during defined frequency and voltage excursions.
4. **Applicability:**
 - 4.1. Generator Owner
5. **Effective Date:**

See the Implementation Plan for PRC-024-2.

B. Requirements

- R1.** Each Generator Owner that has generator frequency protective relaying¹ activated to trip its applicable generating unit(s) shall set its protective relaying such that the generator frequency protective relaying does not trip the applicable generating unit(s) within the “no trip zone” of PRC-024 Attachment 1, subject to the following exceptions:² *[Violation Risk Factor: Medium] [Time Horizon: Long-term Planning]*
- Generating unit(s) may trip if the protective functions (such as out-of-step functions or loss-of-field functions) operate due to an impending or actual loss of synchronism or, for asynchronous generating units, due to instability in power conversion control equipment.
 - Generating unit(s) may trip if clearing a system fault necessitates disconnecting (a) generating unit(s).
 - Generating unit(s) may trip within a portion of the “no trip zone” of PRC-024 Attachment 1 for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.
- R2.** Each Generator Owner that has generator voltage protective relaying¹ activated to trip its applicable generating unit(s) shall set its protective relaying such that the generator voltage protective relaying does not trip the applicable generating unit(s) as a result of a

¹ Each Generator Owner is not required to have frequency or voltage protective relaying (including but not limited to frequency and voltage protective functions for discrete relays, volts per hertz relays evaluated at nominal frequency, multi-function protective devices or protective functions within control systems that directly trip or provide tripping signals to the generator based on frequency or voltage inputs) installed or activated on its unit.

² For frequency protective relays associated with dispersed power producing resources identified through Inclusion I4 of the Bulk Electric System definition, this requirement applies to frequency protective relays applied on the individual generating unit of the dispersed power producing resources, as well as frequency protective relays applied on equipment from the individual generating unit of the dispersed power producing resource up to the point of interconnection.

voltage excursion (at the point of interconnection³) caused by an event on the transmission system external to the generating plant that remains within the “no trip zone” of PRC-024 Attachment 2.⁴ If the Transmission Planner allows less stringent voltage relay settings than those required to meet PRC-024 Attachment 2, then the Generator Owner shall set its protective relaying within the voltage recovery characteristics of a location-specific Transmission Planner’s study. Requirement R2 is subject to the following exceptions: *[Violation Risk Factor: Medium] [Time Horizon: Long-term Planning]*

- Generating unit(s) may trip in accordance with a Special Protection System (SPS) or Remedial Action Scheme (RAS).
- Generating unit(s) may trip if clearing a system fault necessitates disconnecting (a) generating unit(s).
- Generating unit(s) may trip by action of protective functions (such as out-of-step functions or loss-of-field functions) that operate due to an impending or actual loss of synchronism or, for asynchronous generating units, due to instability in power conversion control equipment.
- Generating unit(s) may trip within a portion of the “no trip zone” of PRC-024 Attachment 2 for documented and communicated regulatory or equipment limitations in accordance with Requirement R3.

R3. Each Generator Owner shall document each known regulatory or equipment limitation⁵ that prevents an applicable generating unit with generator frequency or voltage protective relays from meeting the relay setting criteria in Requirements R1 or R2 including (but not limited to) study results, experience from an actual event, or manufacturer’s advice. *[Violation Risk Factor: Lower] [Time Horizon: Long-term Planning]*

3.1. The Generator Owner shall communicate the documented regulatory or equipment limitation, or the removal of a previously documented regulatory or equipment limitation, to its Planning Coordinator and Transmission Planner within 30 calendar days of any of the following:

- Identification of a regulatory or equipment limitation.
- Repair of the equipment causing the limitation that removes the limitation.
- Replacement of the equipment causing the limitation with equipment that removes the limitation.

³ For the purposes of this standard, point of interconnection means the transmission (high voltage) side of the generator step-up or collector transformer.

⁴ For voltage protective relays associated with dispersed power producing resources identified through Inclusion I4 of the Bulk Electric System definition, this requirement applies to voltage protective relays applied on the individual generating unit of the dispersed power producing resources, as well as voltage protective relays applied on equipment from the individual generating unit of the dispersed power producing resource up to the point of interconnection.

⁵ Excludes limitations that are caused by the setting capability of the generator frequency and voltage protective relays themselves but does not exclude limitations originating in the equipment that they protect.

- Creation or adjustment of an equipment limitation caused by consumption of the cumulative turbine life-time frequency excursion allowance.
- R4.** Each Generator Owner shall provide its applicable generator protection trip settings associated with Requirements R1 and R2 to the Planning Coordinator or Transmission Planner that models the associated unit within 60 calendar days of receipt of a written request for the data and within 60 calendar days of any change to those previously requested trip settings unless directed by the requesting Planning Coordinator or Transmission Planner that the reporting of relay setting changes is not required.
[Violation Risk Factor: Lower] [Time Horizon: Operations Planning]

C. Measures

- M1.** Each Generator Owner shall have evidence that generator frequency protective relays have been set in accordance with Requirement R1 such as dated setting sheets, calibration sheets or other documentation.
- M2.** Each Generator Owner shall have evidence that generator voltage protective relays have been set in accordance with Requirement R2 such as dated setting sheets, voltage-time curves, calibration sheets, coordination plots, dynamic simulation studies or other documentation.
- M3.** Each Generator Owner shall have evidence that it has documented and communicated any known regulatory or equipment limitations (excluding limitations noted in footnote 3) that resulted in an exception to Requirements R1 or R2 in accordance with Requirement R3 such as a dated email or letter that contains such documentation as study results, experience from an actual event, or manufacturer's advice.

Each Generator Owner shall have evidence that it communicated applicable generator protective relay trip settings in accordance with Requirement R4, such as dated e-mails, correspondence or other evidence and copies of any requests it has received for that information.

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority

The Regional Entity shall serve as the Compliance Enforcement Authority (CEA) unless the applicable entity is owned, operated, or controlled by the Regional Entity. In such cases, the ERO or a Regional Entity approved by FERC or other applicable governmental authority shall serve as the CEA.

1.2. Data Retention

The following evidence retention periods identify the period of time an entity is required to retain specific evidence to demonstrate compliance. For instances where the evidence retention period specified below is shorter than the time since the last audit, the Compliance Enforcement Authority may ask an entity to provide other evidence to show that it was compliant for the full time period since the last audit.

The Generator Owner shall retain evidence of compliance with Requirement R1 through R4; for 3 years or until the next audit, whichever is longer.

If a Generator Owner is found non-compliant, the Generator Owner shall keep information related to the non-compliance until mitigation is complete and approved for the time period specified above, whichever is longer.

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records.

1.3. Compliance Monitoring and Assessment Processes

Compliance Audit

Self-Certification

Spot Checking

Compliance Investigation

Self-Reporting

Complaint

1.4. Additional Compliance Information

None

2. Violation Severity Levels

| R # | Lower VSL | Moderate VSL | High VSL | Severe VSL |
|-----------|--|--|---|---|
| R1 | N/A | N/A | N/A | The Generator Owner that has frequency protection activated to trip a generating unit, failed to set its generator frequency protective relaying so that it does not trip within the criteria listed in Requirement R1 unless there is a documented and communicated regulatory or equipment limitation per Requirement R3. |
| R2 | N/A | N/A | N/A | The Generator Owner with voltage protective relaying activated to trip a generating unit, failed to set its voltage protective relaying so that it does not trip as a result of a voltage excursion at the point of interconnection, caused by an event external to the plant per the criteria specified in Requirement R2 unless there is a documented and communicated regulatory or equipment limitation per Requirement R3. |
| R3 | The Generator Owner documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 30 calendar days but less than or equal to 60 calendar days of identifying the limitation. | The Generator Owner documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 60 calendar days but less than or equal to 90 calendar days of identifying the limitation. | The Generator Owner documented the known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2 and communicated the documented limitation to its Planning Coordinator and Transmission Planner more than 90 calendar days but less than or equal to 120 calendar days of identifying the limitation. | <p>The Generator Owner failed to document any known non-protection system equipment limitation that prevented it from meeting the criteria in Requirement R1 or R2.</p> <p>OR</p> <p>The Generator Owner failed to communicate the documented limitation to its Planning Coordinator and Transmission Planner within 120 calendar days of identifying the limitation.</p> |

Standard PRC-024-2 — Generator Frequency and Voltage Protective Relay Settings

| R # | Lower VSL | Moderate VSL | High VSL | Severe VSL |
|-----------|--|--|--|--|
| R4 | <p>The Generator Owner provided its generator protection trip settings more than 60 calendar days but less than or equal to 90 calendar days of any change to those trip settings.</p> <p>OR</p> <p>The Generator Owner provided trip settings more than 60 calendar days but less than or equal to 90 calendar days of a written request.</p> | <p>The Generator Owner provided its generator protection trip settings more than 90 calendar days but less than or equal to 120 calendar days of any change to those trip settings.</p> <p>OR</p> <p>The Generator Owner provided trip settings more than 90 calendar days but less than or equal to 120 calendar days of a written request.</p> | <p>The Generator Owner provided its generator protection trip settings more than 120 calendar days but less than or equal to 150 calendar days of any change to those trip settings.</p> <p>OR</p> <p>The Generator Owner provided trip settings more than 120 calendar days but less than or equal to 150 calendar days of a written request.</p> | <p>The Generator Owner failed to provide its generator protection trip settings within 150 calendar days of any change to those trip settings.</p> <p>OR</p> <p>The Generator Owner failed to provide trip settings within 150 calendar days of a written request.</p> |

E. Regional Variances

None

F. Associated Documents

None

Version History


| Version | Date | Action | Change Tracking |
|---------|-------------------|---|---|
| 1 | May 9, 2013 | Adopted by the NERC Board of Trustees | |
| 1 | March 20, 2014 | FERC Order issued approving PRC-024-1. (Order becomes effective on 7/1/16.) | |
| 2 | February 12, 2015 | Adopted by the NERC Board of Trustees | Standard revised in Project 2014-01: Applicability revised to clarify application of requirements to BES dispersed power producing resources |
| 2 | May 29, 2015 | FERC Letter Order in Docket No. RD15-3-000 approving PRC-024-2 | Modifications to adjust the applicability to owners of dispersed generation resources. |

G. References

1. “The Technical Justification for the New WECC Voltage Ride-Through (VRT) Standard, A White Paper Developed by the Wind Generation Task Force (WGTF),” dated June 13, 2007, a guideline approved by WECC Technical Studies Subcommittee.

PRC-024 — Attachment 1

OFF NOMINAL FREQUENCY CAPABILITY CURVE



Curve Data Points:

Eastern Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|---------------------------|------------------------|---------------------------|
| Frequency (Hz) | Time (Sec) | Frequency (Hz) | Time (sec) |
| ≥61.8 | Instantaneous trip | ≤57.8 | Instantaneous trip |
| ≥60.5 | $10^{(90.935-1.45713*f)}$ | ≤59.5 | $10^{(1.7373*f-100.116)}$ |
| <60.5 | Continuous operation | > 59.5 | Continuous operation |

Standard PRC-024-2 — Generator Frequency and Voltage Protective Relay Settings

Western Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|----------------------|------------------------|----------------------|
| Frequency (Hz) | Time (Sec) | Frequency (Hz) | Time (sec) |
| ≥61.7 | Instantaneous trip | ≤57.0 | Instantaneous trip |
| ≥61.6 | 30 | ≤57.3 | 0.75 |
| ≥60.6 | 180 | ≤57.8 | 7.5 |
| <60.6 | Continuous operation | ≤58.4 | 30 |
| | | ≤59.4 | 180 |
| | | >59.4 | Continuous operation |


Quebec Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|----------------------|------------------------|----------------------|
| Frequency (Hz) | Time (Sec) | Frequency (Hz) | Time (Sec) |
| >66.0 | Instantaneous trip | <55.5 | Instantaneous trip |
| ≥63.0 | 5 | ≤56.5 | 0.35 |
| ≥61.5 | 90 | ≤57.0 | 2 |
| ≥60.6 | 660 | ≤57.5 | 10 |
| <60.6 | Continuous operation | ≤58.5 | 90 |
| | | ≤59.4 | 660 |
| | | >59.4 | Continuous operation |

ERCOT Interconnection

| High Frequency Duration | | Low Frequency Duration | |
|-------------------------|----------------------|------------------------|----------------------|
| Frequency (Hz) | Time (Sec) | Frequency (Hz) | Time (sec) |
| ≥61.8 | Instantaneous trip | ≤57.5 | Instantaneous trip |
| ≥61.6 | 30 | ≤58.0 | 2 |
| ≥60.6 | 540 | ≤58.4 | 30 |
| <60.6 | Continuous operation | ≤59.4 | 540 |
| | | >59.4 | Continuous operation |

PRC-024— Attachment 2



Ride Through Duration:

| High Voltage Ride Through Duration | | Low Voltage Ride Through Duration | |
|------------------------------------|--------------------|-----------------------------------|------------|
| Voltage (pu) | Time (sec) | Voltage (pu) | Time (sec) |
| ≥1.200 | Instantaneous trip | <0.45 | 0.15 |
| ≥1.175 | 0.20 | <0.65 | 0.30 |
| ≥1.15 | 0.50 | <0.75 | 2.00 |
| ≥1.10 | 1.00 | <0.90 | 3.00 |

Voltage Ride-Through Curve Clarifications

Curve Details:

1. The per unit voltage base for these curves is the nominal operating voltage specified by the Transmission Planner in the analysis of the reliability of the Interconnected Transmission Systems at the point of interconnection to the Bulk Electric System (BES).
2. The curves depicted were derived based on three-phase transmission system zone 1 faults with Normal Clearing not exceeding 9 cycles. The curves apply to voltage excursions regardless of the type of initiating event.
3. The envelope within the curves represents the cumulative voltage duration at the point of interconnection with the BES. For example, if the voltage first exceeds 1.15 pu at 0.3 seconds after a fault, does not exceed 1.2 pu voltage, and returns below 1.15 pu at 0.4 seconds, then the cumulative time the voltage is above 1.15 pu voltage is 0.1 seconds and is within the no trip zone of the curve.
4. The curves depicted assume system frequency is 60 Hertz. When evaluating Volts/Hertz protection, you may adjust the magnitude of the high voltage curve in proportion to deviations of frequency below 60 Hz.
5. Voltages in the curve assume minimum fundamental frequency phase-to-ground or phase-to-phase voltage for the low voltage duration curve and the greater of maximum RMS or crest phase-to-phase voltage for the high voltage duration curve.

Evaluating Protective Relay Settings:

1. Use either the following assumptions or loading conditions that are believed to be the most probable for the unit under study to evaluate voltage protection relay setting calculations on the static case for steady state initial conditions:
 - a. All of the units connected to the same transformer are online and operating.
 - b. All of the units are at full nameplate real-power output.
 - c. Power factor is 0.95 lagging (i.e. supplying reactive power to the system) as measured at the generator terminals.
 - d. The automatic voltage regulator is in automatic voltage control mode.
2. Evaluate voltage protection relay settings assuming that additional installed generating plant reactive support equipment (such as static VAR compensators, synchronous condensers, or capacitors) is available and operating normally.
3. Evaluate voltage protection relay settings accounting for the actual tap settings of transformers between the generator terminals and the point of interconnection.

Rationale:

During development of this standard, text boxes were embedded within the standard to explain the rationale for various parts of the standard. Upon BOT approval, the text from the rationale text boxes was moved to this section.

Rationale for Footnotes 2 and 4

The SDT has determined it is appropriate to require that protective relay settings applied on both the individual generating units and aggregating equipment (including any non-Bulk Electric System collection system equipment) are set respecting the “no-trip zone” referenced in the requirements to maintain reliability of the BES. If any of the protective relay settings applied on these elements of the facility were to be excluded from this standard, the potential would exist for portions of or the entire generating capacity of the dispersed power producing facility to be lost during a voltage or frequency excursion.

Standard PRC-024-2 — Generator Frequency and Voltage Protective Relay Settings

Appendix QC-PRC-024-2

Provisions specific to Standard PRC-024-2 applicable in Québec

This appendix establishes specific provisions for application of the standard in Québec. Provisions of the standard and of its appendix must be read jointly for the purposes of understanding and interpretation. Where the standard and the appendix differ, the appendix shall prevail.

A. Introduction

1. **Title:** Generator Frequency and Voltage Protective Relay Settings

2. **Number:** PRC-024-2

3. **Purpose:** No specific provisions.

4. **Applicability**

Functions

No specific provisions.

Facilities

This standard applies only to the facilities of the Main Transmission System (RTP).

5. **Effective Dates**

5.1. Adoption of the standard by the Régie de l'énergie: Month xx, 201x

5.2. Adoption of the appendix by the Régie de l'énergie: Month xx, 201x

5.3. Effective date of the standard and its appendix in Québec: January 1, 2019

Implementation Plan for Standard PRC-024-2

| Requirements | Applicability | Implementation date in Québec |
|--------------|--|-------------------------------|
| R1 to R4 | At least 40% of its facilities covered | January 1, 2020 |
| | At least 60% of its facilities covered | January 1, 2021 |
| | At least 80% of its facilities covered | January 1, 2022 |
| | 100% of its facilities covered | January 1, 2023 |

The following changes to the Glossary become effective at the same time as version 2 of the standard (PRC-024): changes to the terms Bulk Electric System (BES), Protection Systems, and Special Protection System (SPS); addition of the term Dispersed Power Producing Resources.

B. Requirements

Replace the first exception to Requirement R2 with the following: “A generating unit may be tripped in accordance with a Remedial Action Scheme (RAS).”

Specific provision regarding Requirement R1: Wind, thermal and photovoltaic generating stations, as well as stations equipped with asynchronous generators, shall adhere to the curves in Attachment 1, as specified by Requirement R1, except that they may be tripped at a frequency of ≥ 61.7 Hz.

Specific provision regarding Requirement R2: Replace references to “PRC-024 Attachment 2” by “QC-PRC-024-2 Attachment 2.”

C. Measures

No specific provisions.

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority

In Québec, the Régie de l'énergie is responsible for compliance monitoring with respect to the reliability standard and its appendix that it adopts.

1.2. Data Retention

No specific provisions.

1.3. Compliance Monitoring and Enforcement Processes

No specific provisions.

1.4. Additional Compliance Information

No specific provisions.

2. Violation Severity Levels

No specific provisions.

E. Regional Variances

No specific provisions.

F. Associated Documents

No specific provisions.

G. References


No specific provisions.

PRC-024 — Attachment 1

No specific provisions.

PRC-024-2 — Attachment 2

Replace the curve and table with the following:



Ride-Through Duration

Standard PRC-024-2 — Generator Frequency and Voltage Protective Relay Settings

Appendix QC-PRC-024-2

Provisions specific to Standard PRC-024-2 applicable in Québec

| High Voltage Ride-Through Duration | | Low Voltage Ride-Through Duration | |
|--|------------|-----------------------------------|------------|
| Voltage (pu) | Time (sec) | Voltage (pu) | Time (sec) |
| >1.4 | 0.033 | $0.9 \leq V \leq 1.10$ | permanent |
| $1.25 < V \leq 1.40$ (Note 1) | 0.10 | $0.85 \leq V < 0.9$ | 30 |
| $1.20 < V \leq 1.25$ | 2.0 | $0.75 \leq V < 0.85$ | 2.0 |
| $1.15 < V \leq 1.20$ | 30.0 | $0.25 \leq V < 0.75$ | 1.0 |
| $1.10 < V \leq 1.15$ | 300 | $0 \leq V < 0.25$ (Note 2) | 0.15 |
| <p>Note 1. Temporary blocking is allowed, after a 0.022 sec delay, when the positive-sequence voltage exceeds 1.25 pu. However, normal operation must resume once the voltage drops back below the 1.25 pu threshold.</p> <p>Note 2. For voltage levels between 0 and 0.25 pu, wind farms must observe the minimum duration calculated with the formula $D = 3.4 V + 0.15$, where D is minimum duration and V is voltage in pu.</p> | | | |

Standard PRC-024-2 — Generator Frequency and Voltage Protective Relay Settings

Appendix QC-PRC-024-2

Provisions specific to Standard PRC-024-2 applicable in Québec

Revision History

| Revision | Date | Action | Change Tracking |
|----------|----------------|--------------|-----------------|
| 0 | Month xx, 201x | New appendix | — |