

## Standard FAC-002-2—Facility Interconnection Studies

### Appendix QC-FAC-002-23-QC-1

#### Specific Provisions specific applicable in Québec for the standard FAC-002-23 applicable in Québec — Facility Interconnection Studies

This appendix establishes specific provisions for the application of the standard in Québec. Provisions of the standard and of ~~its~~this appendix must be read ~~together jointly~~ for ~~the purposes of comprehension understanding~~ and interpretation purposes. Where the standard and appendix differ, the appendix shall prevail.

#### A. Introduction

1. Title: No specific provision~~Facility Interconnection Studies~~

2. Number: No specific provision~~FAC-002-2~~

3. Purpose: No specific provision

4. Applicability:

3.1.4.1. Functional Entities

~~Functions~~

No specific provision

**Facilities**

For the purposes of the standard, Transmission Facilities, Generation Facilities and End-user Facilities are defined as follow:

Transmission Facilities:

- Transmission System operated at 44 kV or above ;
- Any lines from the Transmission System operated at 44 kV or above ;
- Transmission facility operated at 44 kV and above, connected to the Main Transmission System (RTP).

Generation Facilities:

- Any generation facility with an installed capacity of 50 MVA or greater ;
- Any generation facility connected to the Main Transmission System (RTP).

End-user Facilities:

- Addition of a line feeder at 25 kV in a Distribution substation ;
- New connection of an Industrial Customer operated at 44 kV and above, connected to the Main Transmission System (RTP).

4.5. Effective Date:

4.1.5.1. Adoption of the standard by the Régie de l'énergie: \_\_\_\_\_  
~~December 22, 2016~~Month xx, 202x

4.2.5.2. Adoption of ~~the this~~the appendix by the Régie de l'énergie: \_\_\_\_\_  
~~December 22, 2016~~Month xx, 202x

4.3.5.3. Effective date of the standard and ~~its of this~~its appendix in Québec: \_\_\_\_\_  
~~January 1, 2018~~Month xx, 202x

**B. Requirements and Measures**

No specific provision

**C. Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Enforcement Authority**

In Québec, “Compliance Enforcement Authority” means the Régie de l’énergie is responsible, in Québec, for in its role of monitoring and enforcing compliance enforcement with respect to the ~~reliability~~ Reliability standard Standard and its to this appendix that it adopts.

**1.2. Evidence Retention**

No specific provision

**1.3. Compliance Monitoring and Assessment Processes**

No specific provision The Régie de l’énergie establishes the monitoring processes used to evaluate data or information for the purpose of determining compliance or non-compliance with the Reliability Standard and with this appendix.

**1.4. Additional Compliance Information**

No specific provision

**Table of Compliance Elements**

No specific provision

**D. Regional Variances**

No specific provision

**E. Interpretation**

No specific provision

**F. Associated Documents**

No specific provision

**Revision Version History**

<b><u>Revision Ver sion</u></b>	<b><u>Adeoption</u> Date</b>	<b>Action</b>	<b>Change Tracking</b>
<u>01</u>	<u><del>December 22,</del> 2016Month xx, 202x</u>	New appendix <u>as per decision D-XXXX- YYYY.</u>	<u>New</u>